

|          |                      |
|----------|----------------------|
| Facility | XYZ Pharma           |
| Building | Reactor Hall A       |
| Area     | First Floor Room 1B1 |

## SAMPLE ATEX REGISTER - ELECTRICAL

| Module                          | Tag No | Description            | Make | Model | Serial No. | CAT | Concept | Group | Temp class | EPL  | EU /EC Certificate | EU /EC Certificate on file? | Dwg No. | Installed Zone | Suitable Y/N | Applicable Conditions | Date         | By  | Inspection Type  | Closed | Next Inspection<br><small>(Max 3yrs)</small> | Comment |
|---------------------------------|--------|------------------------|------|-------|------------|-----|---------|-------|------------|------|--------------------|-----------------------------|---------|----------------|--------------|-----------------------|--------------|-----|------------------|--------|--|---------|
| Area # 1                        | EL-1A  | Light fitting          |      |       |            | 1G  | Exe     | IIC   | T5         | GbDb |                    | Yes                         |         | 2              | Yes          |                       | 01 July 2020 | ANO | Initial/Detailed | No     | Jul-23                                       |         |
|                                 | HT-1   | Heater                 |      |       |            | 1G  | Exd     | IIB   | T3         | GbDb |                    | No                          |         | 2              | Yes          |                       | 01 July 2020 | ANO | Initial/Detailed | No     | Jul-23                                       |         |
|                                 | Ext-1  | Extract fan            |      |       |            | 1G  | Exde    | IIC   | T3         | GbDb |                    | Yes                         |         | 2              | Yes          |                       | 01 July 2020 | ANO | Initial/Detailed | Yes    | Jul-23                                       |         |
|                                 | JB-1   | Junction box           |      |       |            | 1G  | Exe     | IIA   | T6         | GbDb |                    | Yes                         |         | 2              | Yes          |                       | 01 July 2020 | ANO | Initial/Detailed | Yes    | Jul-23                                       |         |
| Emergency Lighting<br>I.S. 3217 | EXM-1  | Emergency light type 1 |      |       |            |     | Exe     | IIC   | T4         |      |                    | No                          |         | 2              | Yes          |                       | 01 July 2020 | ANO | Initial/Detailed | No     | Jul-23                                       |         |
|                                 | EXM-2  | Emergency light type 2 |      |       |            |     | Exd     | IIB   | T4         |      |                    | No                          |         | 2              | Yes          |                       | 01 July 2020 | ANO | Initial/Detailed | No     | Jul-23                                       |         |
|                                 | EXM-3  | Emergency light type 3 |      |       |            |     | Exde    | IIC   | T5         |      |                    | Yes                         |         | 2              | Yes          |                       | 01 July 2020 | ANO | Initial/Detailed | Yes    | Jul-23                                       |         |
|                                 | EXM-4  | Emergency light type 4 |      |       |            |     | Exn     | IIA   | T4         |      |                    | Yes                         |         | 2              | Yes          |                       | 01 July 2020 | ANO | Initial/Detailed | No     | Jul-23                                       |         |